



SANITARY CERTIFICATE

(Issued under Appendix 3 - Chapter III - Rule 21 under The Tamil Nadu Educational Rules and Table-10 under The Tamil Nadu District Municipalities Building Rules, 1972)

Sub: Schools, College & Education Institute - Sanitary Certificate issued to
**AL MADINAH PUBLIC SCHOOL, CBSE, OLD NO :
487//1,487/2,487/3, T.S.NO-6/2, BLOCK-11, HAJI IBRAHIM
NAGAR, NEAR KAREEM NAGAR, REDDIYARPATTI ROAD,
MELAPALAYAM, TIRUNELVELI-627005**

ROC No. 120/2023/H3

Date: 07.03.2023 ✓

I hereby declare that the accommodation provided in **AL MADINAH PUBLIC SCHOOL, CBSE**, each of the several classes for the minimum number of pupils taught therein is properly ventilated and lighted; that the building is maintained properly; that it is neat and clean; that the latrine arrangements are adequate and satisfactory; that the supply of drinking water is wholesome and all other aspects of sanitation are satisfactory.

This certificate is issued subject to the following conditions:


COVID 19 Appropriate Behavior and Standard Operating Procedures should be scrupulously followed.

1. The garbage generated within the premises should be collected and disposed properly in segregated manner.
2. On any account the garbage should not be burnt.
3. The pupil should be educated to prevent the usage of plastics in the premises.
4. Fire precautionary measures should be maintained properly.
5. Child labour should not be engaged on any account.
6. Shall not cause nuisance to public as per definition under The Tamil Nadu Public Health Act, 1939.
7. Class rooms should not be used as passage.
8. This certificate issued is valid for one year only from the date of issue. This certificate is liable to be cancelled at any time on infringement of any of the above conditions or for improper maintenance of the building or toilets in the premises.

This Certificate is issued for sanitation purpose only and this Certificate valid From 07.03.2023 to 06.03.2024.

Place: Tirunelveli
S. S. Date: 07.03.2023
Principal
M.Sc., M.Ed.

**AL MADINAH PUBLIC SCHOOL
SENIOR SECONDARY AFFILIATED TO CBSE
FILIATION No. 1930845
HAJI IBRAHIM NAGAR, REDDIYARPATTI ROAD,
MELAPALAYAM, TIRUNELVELI - 627 005.**



City Health Officer
Tirunelveli Municipal Corporation

Correspondent
**AL-Madinah Public School - CBSE
Haji Ibrahim Nagar,
Reddiyarpatti Road, Melapalayam,
Tirunelveli - 627 005.**



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Seevalaperi road, Shanthi nagar, Palayamkottai,

Tirunelveli-627002.

Phone: 0462-2914676

Email: jwadwltvl@gmail.com



TC-10748

TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Test Report No:	P/C:2023/TVL/ 00836	Report Date :	25.02.2023
Invoice Details:	8743/Dt.22.02.2023/Amt.Rs.1652/		
URL No	TC1074822000000836F		

Client Name & Address	: Co - ordinator,
Contact No / Email.ID	Al - madinah Public School,
	Melapalayam.
Sample Name	: Water
Sample Description	: RO Water
Sample Submitted by	: Customer – Syed Mohamed
Location & Date	: Above the Address (School Campus) & 22.02.2023
Quantity of sample Received	: 2 Litre
Sample Container	: Plastic – Good condition
Sample Condition on Receipt	: Good
Sample Received On	: 22/02/2023
Test Commenced on	: 22/02/2023
Test Completed on	: 25/02/2023
Environmental Condition	: 25.5 °C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit
1	pH	IS 3025 Part 11-1983	-	5.90	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	IS 3025 Part 21-2009	mg/L	12	200	600
3	Total Alkalinity	IS 3025-Part 23-1986	mg/L	12	200	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	13	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	12	200	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO3 B	mg/L	3	45	45
7	Fluoride as F	APHA 23rd Edition 2017 - 4500- F-D	mg/L	< 0.2	1.0	1.5

S. SYED SULAITHAL PERVEEN M.Sc., M.Ed.,
PRINCIPAL

Note:
5. The test results relate only to the items tested.
6. The test report shall not be reprinted.
AL-MADINAH PUBLIC SCHOOL
SENIOR SECONDARY AFFILIATED TO CBSE
AFFILIATION NO. 1930845
HAJI IBRAHIM NAGAR, REDDIYARPATTI ROAD,
MELAPALAYAM, TIRUNELVELI - 627 005.

Authorised Signatory
Ganesh Kumar. B.E.
Executive Engineer

Correspondent
AL-Madinah Public School - CBSE
Haji Ibrahim Nagar,
Reddiyarpatti Road, Melapalayam,
Tirunelveli - 627 005.